





TRUSS BUILDING



IDENTIFYING EMBLEMS

N.J.A.C. 5:70-2.20(a)1.



“The emblem shall be of a bright and reflective color, or made of reflective material. The shape of the emblem shall be an isosceles triangle and the size shall be 12 inches horizontally by 6 inches vertically. The following letters, of a size and color to make them conspicuous, shall be printed on the emblem, as shown in the diagram below.”



TRUSS FLOOR



TRUSS ROOF



TRUSS FLOOR & ROOF

N.J.A.C. 5:70-2.20(a)2.

“The emblem shall be permanently affixed to the left of the main entrance door at a height between 4 and 6 feet above the ground and shall be installed and maintained by the owner of the building.”

Department of Community Affairs
Division of Fire Safety
P.O. Box 809, Trenton, New Jersey 08625-0809
609.633.6132
609.633.6330 (FAX)